WTCI-347-P

(212) 964-8691

Tishman Realty & Construction Co. Inc.

AS AGENTS FOR THE PORT OF NEW YORK AUTHORITY
WORLD TRADE CENTER
30 CHURCH STREET, NEW YORK, N.Y. 10007

SEPTEMBER 16, 1971

EMERY ROTH & SONS
850 THIRD AVENUE
NEW YORK, NEW YORK

9

ATTENTION: MR. A. CHERRY

RE: WTC 113.00 S.A. #3, SPRAY-ON FIREPROOFING
NORTHEAST PLAZA BUILDING

DEAR SIR:

THIS IS TO CONFIRM OUR TELEPHONE CONVERSATION ON THIS DATE REGARDING FIREPROOFING OF ELEVATOR SHAFT COLUMNS AND BEAMS.

YOU HAVE ADVISED THAT STEEL COLUMNS AND BEAMS WITHIN ELEVATOR SHAFTS DO NOT REQUIRE FIREPROOFING OF ANY KIND.

VERY TRULY YOURS,

TISHMAN REALTY & CONSTRUCTION CO., INC. (AGENT)

R Douglas ejs

RAY DOUGLAS
PROJECT MANAGER
NORTHEAST PLAZA BUILDING

CM/RD/DB
cc: MONTI, WERNEKE, JOHNSON, WRIGHT, P/A

PLAINTIFF'S EXHIBIT
PX-634

THE PORT OF NEW YORK AUTHORITY
OFFICE OF CONSTRUCTION MANAGER

RECEIVED

'71 SEP 20 AM 10:40

PLANNING & CONSTRUCTION DIVISION